



### Automatic Water Supply and Drainage Control

- Ideal for level control of any conductive liquid
- Both general-purpose and panel-use models available
- Incorporates an arrester for surge and induced lightning protection
- Wide range of models: Long-distance, high- and low-sensitivity, two-wire, etc.
- LED indicator for quick operation check
- Conforms to EMC/IEC standards (61F-GP-N/-N8/-GPN-V50)
- UL/CSA approved (61F-GP-N8/-GPN-V50)




### Operating Principle

Unlike ordinary level switches that use a float for level detection, the 61F Floatless Level Controller uses electrodes to electrically detect the liquid level. The following figures illustrate this simple operating principle.




When electrode E1 is not in contact with the conductive liquid, the electrical circuit is open, and no current flows between electrodes E1 and E3.

Consequently, relay X does not operate. Relay X's NC contacts (normally closed, b in the figure) remain closed. However, when liquid is supplied to the tank, so that the liquid contacts or immerses E1, the circuit closes. Relay X operates, and electrical devices connected to the NO (normally open, a in the figure) contacts of the relay begin operation.



A pump is usually connected to a contactor, which in turn is connected to the Controller contact outputs. The Level Controller would automatically operate the pump, to control the liquid level in the tank.

However, in practice, with only two electrodes, ripples on the surface of the liquid cause the Controller to jump and start, shortening pump (and other equipment) life. This problem can be solved by adding another electrode to form a self-holding circuit. The additional electrode, E2, is connected in parallel with E1, as shown below.



As shown in the above figure, when the holding circuit relay is energized, contact a<sub>2</sub>, its NO contact, is closed. The electrical circuit made through the liquid and the electrodes is then retained by E2 and E3, even when the liquid level falls below E1, as long as contact a<sub>2</sub> is closed.


When the liquid level falls below E2, the circuit made through the electrode circuit opens, which de-energizes relay X, thus closing the NC contact of X.

Operating as simply as it does, possible applications of the Floatless Level Controller are virtually endless. Not only liquid level control is possible, but such applications as leakage detection, object size discrimination, and many other problems may be solved by one of the reliable 61F Floatless Level Controllers.


# Model Selection

## ■ Basic Configuration of 61F Conductive Level Controller

To use a 61F Conductive Level Controller, the 61F itself, Electrode Holders, and Electrodes are required.




## Typical Application Example



## Ordering Information

### ■ 61F Controller Selection Guide by Installation Method

#### Standard Model



- When there is sufficient mounting space.
- When monitoring operation through LEDs.

#### Plug-in Model Compact Plug-in Model



- When using socket mounting.

■ 61F Controller Selection Guide by Application

| Item       |   | G   |   | G1  |   |
|------------|---|---|---|---|---|
|            |   | Automatic water supply and drainage control                       |   | Automatic water supply (idling prevention)                                  | Automatic water supply (abnormal shortage alarm)                    |
| Function   | Automatic pump operation (constant water level) |   |   |   |   |
|            | Water level indication abnormal alarm           | ---   |   |   |   |
| Appearance |   | <p>Standard Model</p> <p><b>61F-G</b><br/>(Pages 6 to 10, 52)</p> | <p>Compact Plug-in Model</p> <p><b>61F-GP-N</b><br/>(Pages 18 to 20, 53)</p> <p><b>61F-GP-N8</b><br/>(Pages 21 to 24, 53)</p> | <p>Standard Model</p> <p><b>61F-G1</b><br/>(Pages 6 to 8, 11 to 12, 52)</p> | <p>Plug-in Model</p> <p><b>61F-G1P</b><br/>(Pages 25 to 28, 54)</p> |

| Item       |   | G2  |   | G3  |  |
|------------|---|---|---|---|--|
|            |   | Automatic water supply and drainage control (abnormal water increase alarm) |   | Automatic water supply and drainage control (abnormal filling/shortage alarm) |  |
| Function   | Automatic pump operation (constant water level) |   |   |   |  |
|            | Water level indication abnormal alarm           |   |   |   |  |
| Appearance |   | <p>Standard Model</p> <p><b>61F-G2</b><br/>(Pages 6 to 8, 13, 52)</p>       | <p>Plug-in Model</p> <p><b>61F-G2P</b><br/>(Pages 25 to 26, 29, 30, 54)</p> | <p>Standard Model</p> <p><b>61F-G3</b><br/>(Pages 6 to 8, 14, 53)</p>         |  |


| Item       |  | G4   | I  | Alternative operation of two pumps                                    |   |
|------------|--|--|--|---|---|
|            |  | <b>Water source level indication, prevention of pump idling due to water shortage, automatic water supply control, and indication of water level in tank</b> | <b>Liquid level indication and alarm</b>                       |   |   |
| Function   | <b>Automatic pump operation (constant water level)</b> |  | ---  | ---   |   |
|            | <b>Water level indication abnormal alarm</b>           |  |  | ---   |   |
| Appearance |  | <b>Standard Model</b><br><br><b>61F-G4</b><br>(Pages 6 to 8, 15, 53)   | <b>Standard Model</b><br><br><b>61F-I</b><br>(Pages 6, 17, 52) | <b>Plug-in Model</b><br><br><b>61F-IP</b><br>(Pages 25 to 26, 31, 54) | <b>Compact plug-in Model</b><br><br><b>61F-APN2</b><br>(Pages 34 to 43, 54) |

**Related Products**


Relay Unit for standard models (Page 8)



Surge Suppressor Unit (for protecting against induced voltage) (Pages 44, 54)



61F-WLA Water Leakage Alarm (Pages 68 to 71)










61F-GPN-V50 Water Leakage Detector (Pages 68 to 71)



## ■ Accessories

### Electrode Holders

|                     |   |   |   |   |  |   |   |
|---------------------|---|---|---|---|--|---|---|
| <b>Applications</b> | General applications such as water supply lines                                   | Applications where only a small space is available                                | Liquid with low specific resistance   | Applications where high mounting strength is required                             | Applications where high temperature/high pressure conditions are severe            | Applications where high corrosion resistance is required  | Applications where distance to the water surface is long  |
| <b>Models</b>       | PS-3S/-4S/-5S<br>(Two-wire models are also available.)                            | PS-31   | BF-1  | BF-3/-4/-5  | BS-1   | BS-1T   | PH-1/-2   |
| <b>Appearance</b>   |  |  |  |  |  | <br>SUS<br>Hastelloy<br>titanium | <br>PH-2<br>PH-1 |




### Electrodes

Sets of Electrodes, connecting nuts, lock nuts, and spring washers are available. When ordering individual parts, refer to page 45.



|                     |   |   |   |                                       |  |
|---------------------|---|---|---|---------------------------------------|--|
| <b>Applications</b> | Purified city water, industrial water, sewage | Purified city water, industrial water, sewage, dilute alkaline solution | Sodium hydroxide, acetic acid, dilute sulfuric acid, dilute hydrochloric acid | Sea water, ammonia water, nitric acid | Acetic acid, dilute sulfuric acid, sea water |
| <b>Models</b>       | F03-60-SUS201                                 | F03-60-SUS316   | F03-60 HAS B  | F03-60 HAS C                          | F03-60 Titanium                              |

### Others

| Item   | Model  |
|--|--|
| Protective Cover<br>(for PS or BF electrode holders)<br>                                  | F03-11   |
| Spring Clamp<br>(for PS electrode holders)<br>  | F03-12   |
| Electrode Separators (for preventing long electrodes from contacting with each other)<br> | F03-14 1P (for 1 pole)<br>F03-14 3P (for 3 poles)<br>F03-14 5P (for 5 poles) |

# Specifications

## ■ Standard Models

### Specifications


| Items   | General-purpose Controller<br>61F-□ (TDL)<br>(see note 1 and 2)                   | High-temperature Controller<br>61F-□T<br>(see note 1)  | Long-distance Controllers<br>61F-□L 2KM<br>(for 2 km)<br>61F-□L 4KM<br>(for 4 km)<br>(see note 1)   | High-sensitivity Controllers<br>61F-□H<br>(see note 1)                       | Low-sensitivity Controller<br>61F-□D<br>(see note 1)   | Two-wire Controller<br>61F-□R<br>(see note 1)  |
|---|---|--|---|--|--|--|
| <b>Controlling materials and operating conditions</b> | For control of ordinary purified water or sewage water                            | For control of ordinary purified water or sewage water in cases where the ambient temperature is high. | For control of ordinary purified water in cases where the distance between sewage pumps and water tanks or between receiver tanks and supply tanks is long or where remote control is required. | For control of liquids with high specific resistance such as distilled water | For control of liquids with low specific resistance such as salt water, sewage water, acid chemicals, alkali chemicals | For control of ordinary purified water or sewage water used in combination with Two-wire Electrode Holder (incorporating a resistor of 6.8 kΩ) |
| <b>Supply voltage</b>                                 | 100, 110, 120, 200, 220, 230 or 240 VAC; 50/60 Hz                                 |  |   |  |  |  |
| <b>Operating voltage range</b>                        | 85% to 110% of rated voltage  |  |   |  |  |  |
| <b>Interelectrode voltage</b>                         | 8 VAC   |  |   | 24 VAC   | 8 VAC  |  |
| <b>Interelectrode current</b>                         | Approx. 1 mA AC max.  |  |   |  |  |  |
| <b>Power consumption</b>                              | Approx. 3.2 VA max. (One unit)  |  |   |  |  |  |
| <b>Interelectrode operate resistance</b>              | 0 to approx. 4 kΩ   | 0 to approx. 5 kΩ  | 0 to approx. 1.8 kΩ (for 2 km)<br>0 to approx. 0.7 kΩ (for 4 km)  | Approx. 15 kΩ to 70 kΩ (see note 5)  | 0 to approx. 1.8 kΩ  | 0 to approx. 1.1 kΩ  |
| <b>Interelectrode release resistance</b>              | Approx. 15 k to ∞ Ω   | Approx. 15 k to ∞ Ω  | 4 k to ∞ Ω (for 2 km)<br>2.5 k to ∞ Ω (for 4 km)  | Approx. 300 k to ∞ Ω   | Approx. 5 k to ∞ Ω   | Approx. 15 k to ∞ Ω  |
| <b>Cable length (see note 3)</b>                      | 1 km max.   | 600 m max.   | 2 km max.<br>4 km max.  | 50 m max.  | 1 km max.  | 800 m max.   |
| <b>Control output</b>                                 | 2 A, 220 VAC (Inductive load: $\cos\phi = 0.4$ )<br>5 A, 220 VAC (Resistive load) |  |   |  |  |  |
| <b>Ambient temperature</b>                            | Operating: -10°C to 55°C (-10°C to 70°C for 61F-□T)                               |  |   |  |  |  |
| <b>Ambient humidity</b>                               | Operating: 45% to 85% RH  |  |   |  |  |  |
| <b>Insulation resistance (see note 4)</b>             | 100 MΩ min. (at 500 VDC)  |  |   |  |  |  |
| <b>Dielectric strength (see note 4)</b>               | 2000 VAC, 50/60 Hz for 1 min.   |  |   |  |  |  |
| <b>Life expectancy</b>                                | Electrical: 500,000 operations min.<br>Mechanical: 5,000,000 operations min.      |  |   |  |  |  |

- Note:**
- The □ in the model name represents G, G1, G2, G3, G4, and I.
  - The suffix "TDL" attached to the model name represents models designed for tropical regions (storage humidity of 45 to 90% RH).
  - The length when using completely-insulated, 600-V, 3-conductor (0.75 mm<sup>2</sup>) cable cables. Usable cable lengths will become shorter as the cable diameter or number of conductors becomes larger.
  - The insulation resistance and dielectric strength indicate values between power terminals and Electrode terminals, between power terminals and contact terminals, and between Electrode terminals and contact terminals.
  - Possible to use with 15 kΩ or less, however, this may cause reset failure.


## Internal Circuit Diagrams

The schematic diagrams shown below typify the internal connections of the various 61F models. The designations Ta, Tb, and Tc (sometimes referred to collectively as "U") may occur more than once in a product, however, the "a" terminal is always an NO contact, a "b" terminal is an NC contact, and the "c" terminal is the common terminal.


61F-G




61F-GT




61F-GL




61F-GH  
(See note.)



61F-GD



61F-GR




**Note:** The 61F-11H relay de-energizes when there is water present across the Electrodes, whereas the 61F relay energizes when there is water present across the Electrodes.  
 Also, the terminal connections of those Controllers provided with LED indicators differ from those which have no indicators.


**61F-11 Relay Units**

| Item  | 61F-11 | 61F-11T  | 61F-11L  | 61F-11H      | 61F-11D  | 61F-11R      |
|---|--------|----------|----------|--------------|----------|--------------|
| Interchangeable with general-purpose model (61F-11) | ---    | Provided | Provided | Not provided | Provided | Not provided |
| Color of band on name plate                         | ---    | Red      | Yellow   | Blue         | Black    | Green        |


**61F-11**




**61F-11T**




**61F-11L**




**61F-11H**  
(see note)



**61F-11D**



**61F-11R**







Connections

61F-G


Automatic Water Supply and Drainage Control




1. Water Supply



2. Drainage



- Connect electromagnetic switch coil terminal A to Tb.
- The pump stops (indicator ON) when the water level reaches E1 and starts (indicator OFF) when the water level drops below E2.
- Connect the electromagnetic switch coil terminal A to Ta.
- The pump starts (indicator ON) when the water level reaches E1 and stops (indicator OFF) when the water level drops below E2.




- Note:**
1. The diagram shows the connections for the water supply. When draining, change the connection from terminal Tb to terminal Ta.
  2. Be sure to ground terminal E3.


## 61F-GR

## Two-wire Automatic Water Supply and Drainage Control

## 1. Water Supply




## 2. Drainage



- Connect electromagnetic switch coil terminal A to Tb.
- The pump stops (indicator ON) when the water level reaches E1 and starts (indicator OFF) when the water level drops below E2.


- Connect the electromagnetic switch coil terminal A to Ta.
- The pump starts (indicator ON) when the water level reaches E1 and stops (indicator OFF) when the water level drops below E2.

- Note:**
1. The two-wire models require two cables for connecting the 61F-GR and electrode holders and three electrodes.
  2. The electrode holders must be special ones for two-wire models. (The resistance R is built into the electrode holder for the two-wire models.)




- Note:**
1. The diagram shows the connections for the water supply. When draining, change the connection from terminal Tb to terminal Ta.
  2. Be sure to ground terminal E3.


61F-G1



Application 1: Automatic Water Supply Control with Pump Idling Prevention




- The pump stops (U<sub>2</sub> indicator ON) when the water level reaches E<sub>1</sub> and the pump starts (U<sub>2</sub> indicator OFF) when the water level in the tank drops below E<sub>2</sub>.
- When the level of the water supply source drops below E<sub>2</sub>', the pump stops (U<sub>1</sub> indicator OFF). Pump idling is prevented and the alarm sounds.
- Insert a pushbutton switch (NO contact) between E<sub>1</sub>' and E<sub>3</sub> as shown by the dotted line. When starting the pump or after recovering from a power failure, if the water supply source level has not yet reached E<sub>1</sub>', press the pushbutton switch to start the pump by momentarily short-circuiting E<sub>1</sub>' and E<sub>3</sub>. When the pump stops during normal operation subsequent to an alarm issued for a low water level (e.g., the water level does not reach E<sub>2</sub>'), do not press the pushbutton switch.




Note: Be sure to ground terminal E3.

## 61F-G1

## Application 2: Automatic Water Supply Control with Abnormal Water Shortage Alarm




- The pump stops (U<sub>2</sub> indicator ON) when the water level reaches E<sub>1</sub> and starts (U<sub>2</sub> indicator OFF) when the water level drops below E<sub>2</sub>.
- If the water level drops below E<sub>4</sub> for any reason, the pump stops (U<sub>1</sub> indicator OFF) and the alarm sounds.
- Insert a pushbutton switch (NO contact) between E<sub>3</sub> and E<sub>4</sub>. When starting the pump or after recovering from a power failure, if the water level has not yet reached E<sub>4</sub>, press the pushbutton switch to start the pump by short-circuiting E<sub>3</sub> and E<sub>4</sub>. If the pump stops upon releasing the pushbutton switch, keep pressing the pushbutton switch.



**Note:** Be sure to ground terminal E3.



61F-G2



Automatic Drainage Control and Water Supply with Abnormal Water Increase Alarm

1. Drainage


2. Water Supply



- Connect the electromagnetic switch terminal (T phase) to Ta1.
- The pump starts (U2 indicator ON) when the water level reaches E1 and stops (U2 indicator OFF) when the water level drops below E2.
- If the water level reaches E4 for any reason, the alarm sounds (U1 indicator ON).


- Connect the electromagnetic switch terminal (T phase) to Tb1.
- The pump starts (U2 indicator OFF) when the water level reaches E2 and stops (U2 indicator ON) when the water level rises to E1.
- If the water level reaches E4 for any reason, the alarm sounds (U1 indicator ON).

61F-G2 for drainage control




- Note:**
1. The diagram shows the connections for the water supply. When draining, change the connection from terminal Tb1 to terminal Ta1.
  2. Be sure to ground terminal E3.

61F-G3




Automatic Water Supply and Drainage Control with Abnormal Water Shortage Alarm and Water Tank Repletion

1. Water Supply




2. Drainage




- Connect electromagnetic switch coil terminal A with Tb.
- The pump stops (U2 indicator ON) when the water level reaches E2 and starts (U2 indicator OFF) when the water level drops below E3.
- If the water level rises to E1 for any reason, the upper-limit indicator turns ON and the alarm sounds (U1 indicator ON).
- If the water level drops below E4 for any reason, the lower-limit indicator turns ON and the alarm sounds (U3 indicator OFF).

- Connect the electromagnetic switch coil terminals A with Ta.
- The pump starts (U2 indicator ON) when the water level reaches E2 and stops (U2 indicator OFF) when the water level drops below E3.
- If the water level rises to E1 for any reason, the upper-limit indicator turns ON and the alarm sounds (U1 indicator ON).
- If the water level drops below E4 for any reason, the lower-limit indicator turns ON and the alarm sounds (U3 indicator OFF).




**Note:** 1. The diagram shows the connections for the water supply. When draining, change the connection from terminal Tb to terminal Ta.  
2. Be sure to ground terminal E5.

61F-G4



**Water Source Level Indication, Prevention of Pump Idling Due to Water Shortage, Automatic Water Supply Control, and Indication of Water Level in Tank**

- Insert four Electrodes in the water supply source and five Electrodes in the elevated water tank.
- The lower-limit indicator for the water supply source remains ON while the water source level is below E3 (U2 indicator OFF).
- When the water level rises to E2, the lower-limit indicator turns OFF (U2 indicator ON) and the pump is ready for operation.
- When the water level reaches E1, the upper-limit indicator turns ON (U3 indicator ON).
- The water-shortage indicator for the elevated tank remains ON while the water level in the elevated tank is below E7. The indicator turns OFF (U1 indicator ON) when the water level rises to E7.
- The pump stops (U5 indicator ON) when the water level reaches E5 and starts (U5 indicator OFF) when the water level drops below E6.
- If the water level reaches E4 for any reason, the tank repletion indicator for the elevated tank turns ON (U4 indicator ON).
- Insert a pushbutton switch (NO contact) between E2 and E8 as shown by the dotted line. When starting the pump and after recovering from a power failure, if the water source level has not yet reached E2 (U2 indicator OFF), press the pushbutton switch to start the pump by momentarily short-circuiting E2 and E8. When the pump stops during normal operation subsequent to an alarm issued for low water level (i.e., the water level has not reached E3), do not press the pushbutton switch.



**Note:** 1. Be sure to ground terminal E8.

## ■ Connection with Three-phase Four-line Circuit


When supplying power from N-phase to the Controller in three-phase four-line circuit, refer to the following diagrams.

Line voltage (R-S, S-T, or R-T): 380 or 415 VAC

Phase voltage (N-R, N-S, or N-T): 220 or 240 VAC

### 61F-G□, 220 or 240 VAC


#### Water Supply




**Note:** Be sure to ground terminal E3.




61F-I



Liquid Level Indication and Alarm



- When the water level drops below E<sub>2</sub>, the lower-limit indicator turns ON and the alarm sounds (U<sub>2</sub> indicator OFF).
- When the water level reaches E<sub>2</sub>, the alarm turns OFF and the intermediate indicator turns ON (U<sub>2</sub> indicator ON).
- When the water level rises to E<sub>1</sub>, the upper-limit indicator turns ON and the alarm sounds (U<sub>1</sub> indicator ON).



**Note:** Be sure to ground terminal E3.


## ■ Compact Plug-in Models (11-pin Type)

### Specifications


| Item  | General-purpose Controller<br>61F-GP-N  | High-temperature Controller<br>61F-GP-NT  | Long-distance Controllers<br>61F-GP-NL<br>2KM (for 2 km)<br>61F-GP-NL<br>4KM (for 4 km)   | High-sensitivity Controller<br>61F-GP-NH<br>(see note 1)                     | Low-sensitivity Controller<br>61F-GP-ND  | Two-wire Controller<br>61F-GP-NR   |
|---|---|---|---|--|--|--|
| <b>Controlling materials and operating conditions</b> | For control of ordinary purified water or sewage water                            | For control of ordinary purified water or sewage where operating ambient temperature is high. | For control of ordinary purified water in cases where the distance between sewage pumps and water tanks or between receiver tanks and supply tanks is long or where remote control is required. | For control of liquids with high specific resistance such as distilled water | For control of liquids with low specific resistance such as salt water, sewage water, acid chemicals, alkali chemicals | For control of ordinary purified water or sewage water used in combination with Two-wire Electrode Holder (incorporating a resistor of 6.8 kΩ) |
| <b>Supply voltage</b>                                 | 24, 100, 110, 120, 200, 220, 230 or 240 VAC; 50/60 Hz                             |   |   |  |  |  |
| <b>Operating voltage range</b>                        | 85% to 110% of rated voltage  |   |   |  |  |  |
| <b>Interelectrode voltage</b>                         | 8 VAC   |   |   |  |  |  |
| <b>Interelectrode current</b>                         | Approx. 1 mA AC max.  |   |   | Approx. 0.12 mA AC max.  | Approx. 1 mA AC max.   |  |
| <b>Power consumption</b>                              | Approx. 3.2 VA max.   |   |   |  |  |  |
| <b>Interelectrode operate resistance</b>              | 0 to approx. 4 kΩ   | 0 to approx. 4 kΩ   | 0 to approx. 1.3 kΩ (for 2 km)<br>0 to approx. 0.5 kΩ (for 4 km)  | Approx. 10 kΩ to approx. 40 kΩ (see note 4)                                  | 0 to approx. 1.3 kΩ  | 0 to approx. 2 kΩ  |
| <b>Interelectrode release resistance</b>              | Approx. 15 k to ∞ Ω   | Approx. 15 k to ∞ Ω   | 4 k to ∞ Ω (for 2 km)<br>0.5 k to ∞ Ω (for 4 km)  | Approx. 100 k to ∞ Ω   | Approx. 4 k to ∞ Ω   | Approx. 15 k to ∞ Ω  |
| <b>Response time</b>                                  | Operate: 80 ms max.<br>Release: 160 ms max.                                       |   |   |  |  |  |
| <b>Cable length (see note 2)</b>                      | 1 km max.   | 600 m max.  | 2 km max.<br>4 km max.  | 50 m max.  | 1 km max.  | 800 m max.   |
| <b>Control output</b>                                 | 1 A, 250 VAC (Inductive load: $\cos\phi = 0.4$ )<br>3 A, 250 VAC (Resistive load) |   |   |  |  |  |
| <b>Ambient temperature</b>                            | Operating: -10°C to 55°C (-10°C to 70°C for high-temperature controller)          |   |   |  |  |  |
| <b>Ambient humidity</b>                               | Operating: 45% to 85% RH  |   |   |  |  |  |
| <b>Insulation resistance (see note 3)</b>             | 100 MΩ min. (at 500 VDC)  |   |   |  |  |  |
| <b>Dielectric strength (see note 3)</b>               | 2000 VAC, 50/60 Hz for 1 min.   |   |   |  |  |  |
| <b>Life expectancy</b>                                | Electrical: 100,000 operations min.<br>Mechanical: 5,000,000 operations min.      |   |   |  |  |  |

- Note:**
- The relay in the 61F-GP-NH de-energizes when there is water present across the Electrodes, whereas the relay in the 61F-GP-N8HY energizes when there is water present across the Electrodes.
  - The length when using completely-insulated, 600-V, 3-conductor (0.75 mm<sup>2</sup>) cable cables. Usable cable lengths will become shorter as the cable diameter or number of conductors becomes larger.
  - The insulation resistance and dielectric strength indicate values between power terminals and Electrode terminals, between power terminals and contact terminals, and between Electrode terminals and contact terminals.
  - Possible to use with 10 kΩ or less, however, this may cause reset failure.


**Internal Circuit Diagrams**  
61F-GP-N/-NT/-NL/-ND



**61F-GP-NH**



**61F-GP-NR**



**Note:** When applying a self-holding circuit, short between terminals 5 and 6 and use terminal 7 as E<sub>2</sub>.


**Connections**

**61F-GP-N**




**Automatic Water Supply and Drainage Control**

**1. Water Supply**




- Connect electromagnetic switch coil terminal A to terminal 1.
- The pump stops when the water level reaches E1 (indicator ON) and starts when the water level drops below E2 (indicator OFF).

**2. Drainage**



- Connect the electromagnetic switch coil terminal to terminal 11.
- Pump starts when the water level reaches E1 (indicator ON) and stops when the water level drops below E2 (indicator OFF).



- Note:**
1. The diagram shows the connections for the water supply. When draining, change the connection from terminal 1 to terminal 11.
  2. Be sure to ground terminal 4.


## ■ Connection with Three-phase Four-line Circuit

When supplying power from N-phase to the Controller in three-phase four-line circuit, refer to the following diagrams.

Line voltage (R-S, S-T, or R-T): 380 or 415 VAC

Phase voltage (N-R, N-S, or N-T): 220 or 240 VAC

61F-GP-N□ 220 or 240 VAC



- Note:**
1. The diagram shows the connections for the water supply. When draining, change the connection from terminal 1 to terminal 11.
  2. Be sure to ground terminal 4.

## ■ Compact Plug-in Models (8-pin Type)




### Specifications

| Item  | General-purpose Controller<br>61F-GP-N8<br>61F-GP-N8Y<br>(see note 1)             | Long-distance Controllers<br>61F-GP-N8L<br>2KM (for 2 km)<br>61F-GP-N8L<br>4KM (for 4 km)   | High-sensitivity Controllers<br>61F-GP-N8H<br>61F-GP-N8HY<br>(see note 1)    | Low-sensitivity Controller<br>61F-GP-N8D   | Two-wire Controller<br>61F-GP-N8R   | Variable Sensitivity Controller<br>61F-GP-N8-V50   |
|---|---|---|--|--|---|--|
| <b>Controlling materials and operating conditions</b> | For control of ordinary purified water or sewage water                            | For control of ordinary purified water in cases where the distance between sewage pumps and water tanks or between receiver tanks and supply tanks is long or where remote control is required. | For control of liquids with high specific resistance such as distilled water | For control of liquids with low specific resistance such as salt water, sewage water, acid chemicals, alkali chemicals | For control of ordinary purified water or sewage water used in combination with Two-wire Electrode Holder (incorporating a resistor of 6.8 k $\Omega$ ) | For control of cases where variable sensitivity control is required such as detection of froth on the surface of a liquid, control of soil moisture content, or detection of degree of water pollution |
| <b>Supply voltage</b>                                 | 24, 100, 110, 120, 200, 220, 230 or 240 VAC; 50/60 Hz                             |   |  |  |   | 24, 110, 220 or 240 VAC; 50/60 Hz  |
| <b>Operating voltage range</b>                        | 85% to 110% of rated voltage  |   |  |  |   |  |
| <b>Interelectrode voltage</b>                         | 8 VAC   |   | 24 VAC   | 8 VAC  |   | 24 VAC   |
| <b>Interelectrode current</b>                         | Approx. 1 mA AC max.  |   | Approx. 0.4 mA AC max.   | Approx. 1 mA AC max.   |   | Approx. 3 mA AC max.   |
| <b>Power consumption</b>                              | Approx. 3.5 VA max.   |   |  |  |   |  |
| <b>Interelectrode operate resistance</b>              | 0 to approx. 4 k $\Omega$   | 0 to 1.3 k $\Omega$ (for 2 km)<br>0 to 0.5 k $\Omega$ (for 4 km)  | Approx. 15 k $\Omega$ to approx. 70 k $\Omega$ (see note 4)                  | 0 to approx. 1.3 k $\Omega$  | 0 to approx. 2 k $\Omega$   | 0 to 50 k $\Omega$ (Variable)  |
| <b>Interelectrode release resistance</b>              | Approx. 15 k to $\infty$ $\Omega$   | 4 k to $\infty$ $\Omega$ (for 2 km)<br>0.5 k to $\infty$ $\Omega$ (for 4 km)  | Approx. 300 k to $\infty$ $\Omega$   | Approx. 4 k to $\infty$ $\Omega$   | Approx. 15 k to $\infty$ $\Omega$   | Operating resistance +50 k $\Omega$ max.   |
| <b>Response time</b>                                  | Operate: 80 ms max.<br>Release: 160 ms max.                                       |   |  |  |   |  |
| <b>Cable length (see note 2)</b>                      | 1 km max.   | 2 km max.<br>4 km max.  | 50 m max.  | 1 km max.  | 800 m max.  | 50 m max.  |
| <b>Control output</b>                                 | 1 A, 250 VAC (Inductive load: $\cos\phi = 0.4$ )<br>3 A, 250 VAC (Resistive load) |   |  |  |   |  |
| <b>Ambient temperature</b>                            | Operating: -10°C to 55°C  |   |  |  |   |  |
| <b>Ambient humidity</b>                               | Operating: 45% to 85% RH  |   |  |  |   |  |
| <b>Insulation resistance (see note 3)</b>             | 100 M $\Omega$ min. (at 500 VDC)  |   |  |  |   |  |
| <b>Dielectric strength (see note 3)</b>               | 2000 VAC, 50/60 Hz for 1 min.   |   |  |  |   |  |
| <b>Life expectancy</b>                                | Electrical: 100,000 operations min.<br>Mechanical: 5,000,000 operations min.      |   |  |  |   |  |

- Note:**
1. The relay in the 61F-GP-N8H/-N8Y de-energizes when there is water present across the Electrodes, whereas the relay in the 61F-GP-N8HY energizes when there is water present across the Electrodes.
  2. The length when using completely-insulated, 600-V, 3-conductor (0.75 mm<sup>2</sup>) cable cables. Usable cable lengths will become shorter as the cable diameter or number of conductors becomes larger.
  3. The insulation resistance and dielectric strength indicate values between power terminals and Electrode terminals, between power terminals and contact terminals, and between Electrode terminals and contact terminals.
  4. Possible to use with 10 k $\Omega$  or less, however, this may cause reset failure.


**Internal Circuit Diagrams**

**61F-GP-N8/-N8L/-N8D/-N8HY**




**Note:** 24 V for the 61F-GP-N8HY.

**61F-GP-N8Y**



**61F-GP-N8-V50**




Connections

61F-GP-N8




Automatic Water Supply and Drainage Control


1. Water Supply



2. Drainage



- Connect electromagnetic switch coil terminal A to terminal 2.
- The pump stops when the water level reaches E1 (indicator ON) and starts when the water level drops below E2 (indicator OFF).
- Connect the electromagnetic switch coil terminal A to terminal 3.
- The pump starts when the water level reaches E1 (indicator ON) and stops when the water level drops below E2 (indicator OFF).



- Note:**
1. The diagram shows the connections for the water supply. When draining, change the connection from terminal 2 to terminal 3.
  2. The ground terminal must be grounded.


## ■ Connection with Three-phase Four-line Circuit

When supplying power from N-phase to the Controller in three-phase four-line circuit, refer to the following diagrams.

Line voltage (R-S, S-T, or R-T): 380 or 415 VAC

Phase voltage (N-R, N-S, or N-T): 220 or 240 VAC

### 61F-GP-N8□, 220 or 240 VAC



**Note:** Be sure to ground terminal 1.



## ■ Plug-in Models


### Specifications

| Item  | General-purpose Controller<br>61F-G1P<br>61F-G2P<br>61F-IP                        | Long-distance Controllers<br>61F-G1PL<br>61F-G2PL<br>61F-IPL<br>(see note 2)  | High-sensitivity Controllers<br>61F-G1PH<br>61F-G2PH<br>61f-IPH<br>(see note 1) | Low-sensitivity Controller<br>61F-G1PD<br>61F-G2PD<br>61F-IPD  |
|---|---|---|---|--|
| <b>Controlling materials and operating conditions</b> | For control of ordinary purified water or sewage water                            | For control of ordinary purified water in cases where the distance between sewage pumps and water tanks or between receiver tanks and supply tanks is long or where remote control is required. | For control of liquids with high specific resistance such as distilled water    | For control of liquids with low specific resistance such as salt water, sewage water, acid chemicals, alkali chemicals |
| <b>Supply voltage</b>                                 | 100, 110, 120, 200, 220, 230 or 240 VAC; 50/60 Hz                                 |   |   |  |
| <b>Operating voltage range</b>                        | 85% to 110% of rated voltage  |   |   |  |
| <b>Interelectrode voltage</b>                         | 8 VAC   |   | 24 VAC  | 8 VAC  |
| <b>Interelectrode current</b>                         | Approx. 1 mA AC max.  |   | Approx. 0.4 mA AC max.  | Approx. 1.2 mA AC max.   |
| <b>Power consumption</b>                              | Approx. 6.4 VA max.   |   |   |  |
| <b>Interelectrode operate resistance</b>              | 0 to approx. 4 kΩ   | 0 to 1.8 kΩ (for 2 km)<br>0 to 0.7 kΩ (for 4 km)  | Approx. 15 kΩ to approx. 70 kΩ<br>(see note 5)                                  | 0 to approx. 1.8 kΩ  |
| <b>Interelectrode release resistance</b>              | Approx. 15 k to ∞ Ω   | 4 k to ∞ Ω (for 2 km)<br>2.5 k to ∞ Ω (for 4 km)  | Approx. 300 k to ∞ Ω  | Approx. 5 k to ∞ Ω   |
| <b>Response time</b>                                  | Operate: 80 ms max.<br>Release: 160 ms max.                                       |   |   |  |
| <b>Cable length (see note 3)</b>                      | 1 km max.   | 2 km max.<br>4 km max.  | 50 m max.   | 1 km max.  |
| <b>Control output</b>                                 | 2 A, 200 VAC (Inductive load: $\cos\phi = 0.4$ )<br>5 A, 200 VAC (Resistive load) |   |   |  |
| <b>Ambient temperature</b>                            | Operating: -10°C to 55°C  |   |   |  |
| <b>Ambient humidity</b>                               | Operating: 45% to 85% RH  |   |   |  |
| <b>Insulation resistance (see note 4)</b>             | 100 MΩ min. (at 500 VDC)  |   |   |  |
| <b>Dielectric strength (see note 4)</b>               | 2000 VAC, 50/60 Hz for 1 min.   |   |   |  |
| <b>Life expectancy</b>                                | Electrical: 500,000 operations min.<br>Mechanical: 5,000,000 operations min.      |   |   |  |


- Note:**
1. The relay in the 61F-G1H/-G2H/-IPH de-energizes when there is water present across the Electrodes, whereas the relay in the 61F-GP-N8HY energizes when there is water present across the Electrodes.
  2. Models are available for 2 km and 4 km.
  3. The length when using completely-insulated, 600-V, 3-conductor (0.75 mm<sup>2</sup>) cable cables. Usable cable lengths will become shorter as the cable diameter or number of conductors becomes larger.
  4. The insulation resistance and dielectric strength indicate values between power terminals and Electrode terminals, between power terminals and contact terminals, and between Electrode terminals and contact terminals.
  5. Possible to use with 15 kΩ or less, however, this may cause reset failure.

Internal Circuit Diagrams


61F-G1P/-G1PL/-G1PD




61F-G1PH




61F-G2P/-G2PL/-G2PD




61F-G2PH



61F-IP/-IPL/-IPD




61F-IPH




Connections


61F-G1P



Application 1: Automatic Water Supply Control with Pump Idling Prevention




- The pump stops when the water level reaches E1 and the pump starts when the water level in the tank drops below E2.
- When the level of water supply source drops below E2', the pump stops. Pumping idling is prevented and the alarm sounds.
- Insert a pushbutton switch (NO contact) between 11 and 15 as shown by the dotted line below. When starting the pump and after recovering from a power failure, if the water supply source level has not yet reached E1', press the pushbutton switch to start the pump by momentarily short-circuiting E1' and E3. When the pump stops during normal operation subsequent to an alarm issued for a low water level, do not press the pushbutton switch.




**Note:** Be sure to ground terminal 15.

## 61F-G1P

## Application 2: Automatic Water Supply Control with Abnormal Water Shortage Alarm



- The pump stops when the water level reaches E1 and starts when the water level drops below E2.
- If the water level drops below E4 for any reason, the pump stops and the alarm sounds.
- Insert a pushbutton switch (NO contact) between 11 and 15.
- When starting the pump and after recovering from a power failure, if the water level has not yet reached E4, press the pushbutton switch to start the pump by short-circuiting E3 and E4.
- If the pump stops upon release of the pushbutton switch, keep pressing the pushbutton switch.




**Note:** Be sure to ground terminal 15.




61F-G2P

Application 2: Water Supply




- Connect the terminal 6 to terminal 9 (power supply line).
- The pump starts when the water level reaches E2, and stops when the water level rises to E1.
- If the water level reaches E4 for any reason, the alarm sounds.




**Note:** Be sure to ground terminal 15.


61F-IP



Liquid Level Indication and Alarm



- When the water level drops below E2, the lower-limit indicator turns ON and the alarm sounds.
- When the water level reaches E2, the indicator turns OFF and the intermediate indicator turns ON.
- When the water level rises to E1, the upper-limit indicator turns ON and the alarm sounds.



**Note:** Be sure to ground terminal 15.

## ■ Ultra High-sensitivity Models

Use these models for sensing objects such as ice, high-purity distilled water, moisture, or other objects with low electrical conductivity.


### Specifications

| Item                              | High-sensitivity 61F-UHS  | Variable high-sensitivity 61F-HSL   |
|-----------------------------------|---|---|
| Supply voltage                    | 100, 200, or 220 VAC; 50/60 Hz  | 24, 100, 110, 200, or 220 VAC; 50/60 Hz   |
| Operating voltage range           | 85% to 110% of rated voltage  |   |
| Interelectrode voltage            | 24 VAC  | 13 VDC max.   |
| Interelectrode current            | Approx. 1 mA AC max.  | Approx. 1 mA DC max.  |
| Power consumption                 | 3.2 VA max.   |   |
| Interelectrode operate resistance | 0 to approx. 1 M $\Omega$ (see note 1)  | 0 to approx. 5 M $\Omega$ (variable)  |
| Interelectrode release resistance | Approx. 5 M $\Omega$ to $\infty$ $\Omega$   | Operate resistance + 2.5 M $\Omega$ max.  |
| Cable length                      | 5 m (see note 2)  | Note 3  |
| Control output                    | 0.3 A, 220 VAC (Inductive load: $\cos\phi = 0.4$ )<br>1 A, 220 VAC (Resistive load) | 2 A, 220 VAC (Inductive load: $\cos\phi = 0.4$ )<br>5 A, 220 VAC (Resistive load) |
| Ambient temperature               | Operating: -10°C to 55°C  |   |
| Ambient humidity                  | Operating: 45% to 85% RH  |   |
| Insulation resistance             | 100 M $\Omega$ max. (at 500 VDC)  |   |
| Dielectric strength               | 2,000 VAC, 50/60 Hz for 1 min   |   |
| Life expectancy                   | Electrical: 50,000 operations min.<br>Mechanical: 5,000,000 operations min.         | Electrical: 500,000 operations min.<br>Mechanical: 5,000,000 operations min.      |


- Note:**
- Use 61F-UHS for detecting water leakage with high specific resistance. Connect a sensor cable (page 69) between terminals 1 and 7.
  - Two Electrodes can be connected to the 61F-HSL. Use them for an alarm, not for creating a self-holding circuit.
  - The length when using completely-insulated, 600-V, 3-conductor (0.75 mm<sup>2</sup>) cable cables. Usable cable lengths will become shorter as the cable diameter or number of conductors becomes larger. For more details, refer to *Short Wiring in Electrode Circuit* on page 65.
  - It is recommended that the cable length be kept as short as possible since the Electrode circuit current is at DC micro-current level. Moreover, the Electrodes will corrode rapidly if the current is allowed to constantly flow between the Electrodes. Be careful with the electrode polarity and grounding when wiring.

### Internal Circuit Diagrams

#### 61F-UHS




#### 61F-HSL






External Circuit Diagrams (Example)

61F-UHS



Socket: 8PFA1 (track mounted)/  
PL08 (back connecting)

61F-HSL




Socket: 8PFA (track mounted)/  
PL08 (back connecting)


61F-UHS

Automatic Operation for Water Supply and Drainage

1. Water Supply




2. Water Drainage



- Operation: When the water level reaches E1, the pump stops and, when the water level reaches E2 or below, the pump starts.
- Connection: Connect the contactor coil terminal to terminal 2 of the plug-in model. (Terminal 3 is not used.)


- Operation: When the water level reaches E1, the pump starts and, when the water level reaches E2 or below, the pump stops.
- Connection: Connect the contactor coil terminal to terminal 3 of the plug-in model. (Terminal 2 is not used.)



Be sure to ground terminal 1.

## ■ 61F-APN2 Solid-state Alternate Operation Relay

When operating two pumps alternately for controlling the one-point liquid level, use the Relay in combination with 61F Controller.



61F-APN2 Compact Plug-in Model

### Specifications

#### Ratings

|                         |                                  |
|-------------------------|----------------------------------|
| Supply voltage          | 100, 110, 200, 220 VAC; 50/60 Hz |
| Operating voltage range | 85% to 110% of rated voltage     |
| Power consumption       | 3 VA                             |

#### Contact Ratings (With G2RK Keep Relay)

| Item                    | Resistive load ( $\cos\phi = 1$ ) | Inductive load ( $\cos\phi = 0.4$ , L/R = 7 ms) |
|-------------------------|-----------------------------------|---|
| Max. load               | 3 A at 250 VAC                    | 1.5 A at 250 VAC                                |
| Carry contact           | 3 A                               |   |
| Max. operating current  | 3 A                               |   |
| Max. switching capacity | 750 VA                            | 375 VA  |

#### Characteristics


|                       |  |
|-----------------------|--|
| Response time         | Operate: 25 ms max.<br>Release: 30 ms max.   |
| Minimum pulse width   | Min. ON time: 40 ms min.<br>Min. OFF time: 200 ms min.   |
| Insulation resistance | 100 M $\Omega$ min. at 500 VDC (between each terminal and power supply)  |
| Dielectric strength   | 2,000 VAC, 50/60 Hz for 1 min (between each terminal and power supply)   |
| Vibration resistance  | 10 to 55 Hz, 1-mm double amplitude   |
| Shock resistance      | 10 G (approx. 98 m/s <sup>2</sup> )  |
| Life expectancy       | Mechanical: 1,000,000 operations (at operating frequency of 1,800 operations/hour)<br>Electrical: 100,000 operations min. (rated load) |
| Ambient temperature   | Operating: -10°C to 55°C   |
| Ambient humidity      | Operating: 45% to 85% RH   |

When power is applied to the input terminals 2 and 7, the power will be transmitted through the alternate operation control circuit and output circuit to turn ON the contacts (NO condition) between 1 and 3 and between 6 and 8. This state will be held by a magnetic lock even when the power to the input terminals is turned OFF.

When power is again applied to the input terminals, the contact (NO condition) will turn OFF and the contacts (NC condition) between 1 and 4 and between 5 and 8 will turn ON. This state will be held even when the power to the input terminals is turned OFF.

The above operation repeats each time power is applied to the input terminals (power application pulse response system). Refer to the following internal circuit diagram.

#### Internal Circuit Diagram




Connect the output terminal Ta of the 61F-G□ to input terminal 2 of the 61F-APN2.


### Connection

Connect the contactor coil terminal A to the switching contact terminals 3 and 4 of the 61F-APN2.

Operation of the two pumps can be displayed using the switching contact terminals 5 and 6 of the 61F-APN2.



### Timing Chart of Water Supply Alternate Operation



When the 61F-APN2 Alternate Operation Relay is used in combination with a 61F Controller, the output contacts of the Alternate Operation Relay will not be switched (OFF) while the contactor is being excited, and the contactor will not be excited (ON) at the moment when the output contacts are switched. That is, loads such as contactors will not be directly turned ON or OFF by the actions of the output contacts of the 61F-APN2 Alternate Operation Relay. Instead, they will be turned ON or OFF by the actions of the 61F Controller.


In case of water supply operation, the output contacts of the Alternate Operation Relay will be switched after the normally closed contacts of the 61F turn OFF upon reaching the control level, and the output contacts will be already switched when the normally closed contacts of the 61F turn OFF next time.

Therefore, only the continuous line current needs to be considered as the load capacity of the 61F-APN2 and the current can be applied up to the rated line current of 3 A.

Connections


At 200 VAC

Water Supply (When Combined with 61F-G)




\*Be sure to ground terminal E3.

**Note:** When controlling drainage, change the connections as shown by dotted lines in the following illustration.




Water Supply (When Combined with 61F-G1)



\*Be sure to ground terminal E3.


**Note:** The 61F-G1 is to be used only for supplying water and cannot be used for alternate operation for controlling drainage.

Water Drainage (When Combined with 61F-G2)




\*Be sure to ground terminal E3.

**Note:** When supplying water, change the two connections as shown by dotted lines in the following illustration.




Water Supply (When Combined with 61F-G3)




\*Be sure to ground terminal E3.

**Note:** When discharging water, change the two connections as shown by dotted lines in the following illustration.



Water Supply (When Combined with 61F-G4)




\*Be sure to ground terminal E3.

**Note:** The 61F-G4 is to be used only for supplying water and cannot be used alternately for controlling drainage.



At 220 VAC


Water Supply (When Combined with 61F-G1P)



\*Be sure to ground terminal 15.


### Water Supply (When Combined with 61F-GP-N)

For example, operation indication is possible by the connection as shown by the dotted line.



\*Be sure to ground terminal 4.

### Water Drainage (When Combined with 61F-G2P)



## ■ 61F-03B/04B Surge Suppressor Unit


A high-capacity protective device is available which protects 61F-series Floatless Level Controllers against faults arising from electrical surges (such as indirect strokes of lightning) when the Controllers are employed in elevated water tanks or in high-altitude locations.

### Specifications


|                           |                            |
|---------------------------|----------------------------|
| Discharge start voltage   | 90 V $\pm$ 20 VDC          |
| Impulse withstand voltage | 200,000 V (1 x 40 $\mu$ s) |
| Impulse withstand current | 6,000 A (1 x 40 $\mu$ s)   |

### Internal Connections

61F-03B




61F-04B



### Precautions

1. Mount the Surge Suppressor Unit as close to the Controller as possible. Adequate results may not be obtained if mounted close to the Electrode Holder.
2. When grounding the Surge Suppressor Unit in the vicinity of the Controller, connect the ground side of the Surge Suppressor Unit to Electrode E3, E5, or E8 (ground terminal).







### Connection Sockets

PF113A-E Track-mounted Socket






PL11 Back-connecting Socket

## ■ Accessories (Order Separately)

### Electrode Holders

|                           |  |  |   |   |                        |
|---------------------------|--|--|---|---|------------------------|
| <b>Applications</b>       | For city water and other General-use Electrodes. Easy-to-replace separate versions facilitate maintenance of Electrodes. | When mounting space is limited. Special 3-pole holder of small size and light weight. Ideal for soft drink vendors, etc., where only limited space is available. | For low specific liquids. Used for sewage, sea water, etc., having a low specific resistance. In sewage use, Electrode Holders must be installed 10 to 20 cm apart from one another. For acids, alkalis and sea water, Electrode Holders may be as much as 1 meter apart to operate properly. | When secure installation is required. For sewage, city water and other general use. 3-, 4-, and 5-pole models are available. In outdoor or dusty locations, or locations subject to water splashes, adherence of water, dust, dirt, or other foreign matter to the Electrode insulator may cause Controller malfunctioning due to leakage. Be sure to use the Protective Cover. |                        |
| <b>Mounting style</b>     | Flange   | Screw  | Flange  |   |                        |
| <b>Insulator material</b> | Phenol resin   |  | Ceramics  |   |                        |
| <b>Max. temperature</b>   | 70°C max.  |  | 150°C max. (without water drips or vapor on the surface of the Electrode Holder)  | 150°C max.  |                        |
| <b>Appearance</b>         | PS-3S(R)<br>PS-4S(R)<br>PS-5S(R)<br>    | PS-31<br><br>(see note 2)   | BF-1<br>  | BF-3(R)<br>BF-4(R)<br>BF-5(R)<br><br>Heat re-sisting temp. 70°C<br>Heat re-sisting temp. 150°C   |                        |
| <b>No. of Electrodes</b>  | 1  | ---  | ---   | BF-1  | ---                    |
|                           | 3  | PS-3S(-3SR) (see note 1)   | PS-31   | ---   | BF-3(-3R) (see note 2) |
|                           | 4  | PS-4S(-4SR) (see note 1)   | ---   | ---   | BF-4(-4R) (see note 2) |
|                           | 5  | PS-5S(-5SR) (see note 1)   | ---   | ---   | BF-5(-5R) (see note 2) |

- Note:** 1. Those with the suffix R in their model name are for 2-wire circuits.  
2. The Electrode material for PS-31 is SUS304. (Length: 300 mm)


|                           |  |   |  |   |      |
|---------------------------|--|---|--|---|------|
| <b>Applications</b>       | When resistance to high pressure is required. Ideal for use in tanks where temperature or pressure inside the tank is high, e.g. 250°C, 1.96 MPa {20 kg/cm <sup>2</sup> }  | When corrosion resistance is required. Since Teflon is used as the main part, the Electrode is free from rust and corrosion. Ideal for liquid level control in food processing, level control of strong alkaline liquids, etc. Withstand pressure: 981 kPa {10 kg/cm <sup>2</sup> } | When Electrode positions are distant from water surface. For deep well, especially sewage. Several Electrodes are used in combination. Cable length: 100 m max. Single-core cord of 0.75 mm <sup>2</sup> (30/0.18) provided. | When Electrode positions are distant from water surface. For deep well and underwater pump. 2 sets of special Electrodes attached to cable are to be suspended in water. Cable length: 100 m max. Two-core cord of 0.75 mm <sup>2</sup> (30/0.18) provided. |      |
| <b>Mounting style</b>     | Screw  |   | ---  |   |      |
| <b>Insulator material</b> | Teflon   |   | ---  |   |      |
| <b>Max. temperature</b>   | 250°C max. (without water drips or vapor on the surface of the Electrode Holder)   | 150°C max.  | With vinyl cord: -10°C to 60°C<br>With chloroprene cord: -30°C to 70°C (without frost formation)   |   |      |
| <b>Appearance</b>         | <br>Maximum tightening torque at the terminal: 14 kg•cm (137.2 N)<br>Material at tightening section: iron (standard), SUS304, SUS316<br>Heat re-sisting temp.: 150 °C | SUS<br><br>Hastelloy titanium<br>   |   |    |      |
| <b>No. of Electrodes</b>  | 1  | BS-1  | BS-1T  | PH-1  | ---  |
|                           | 2  | ---   | ---  | ---   | PH-2 |

- Note:**
1. The BS-1 and BS-1T are pressure-proof models. The rest of models are not pressure-proof.
  2. The BS-1 that uses SUS304 for clamping sections and screws of PT1/2 specifications is called BS-1S1.
  3. The BS-1 that uses SUS304 for clamping sections is called BS-1S and one that uses SUS316 is called BS-1S2.
  4. When using the BS-1T in liquids with low specific resistance, provide a large clearance between Electrodes. This clearance must be varied depending on the specific resistance, for example, approximately 1 m for acid or alkali liquids.

### Electrodes, Connecting Nuts, and Lock Nuts

| Applicable liquids  | Material                         | Electrode assembly | Models for individual Electrode assembly components |         |                 |       |               |       |               |
|---|----------------------------------|--------------------|---|---------|-----------------|-------|---------------|-------|---------------|
|   |                                  |                    | Electrode (1 m long)                                |         | Connecting nut  |       | Lock nut      |       | Spring washer |
|   |                                  |                    | Model   | Model   | Indication mark | Model | Inscription   | Model | Inscription   |
| Purified city water, industrial water, sewage                                 | Equivalent to SUS 304 (AISI-304) | F03-60 SUS201      | F03-01 SUS201                                       | 1 line  | F03-02 SUS201   | ---   | F03-03 SUS201 | ---   | F03-04 SUS201 |
| Purified city water, industrial water, sewage, dilute alkaline solution       | SUS316 (AISI-316)                | F03-60 SUS316      | F03-01 SUS316                                       | 2 lines | F03-02 SUS316   | 6     | F03-03 SUS316 | 316   | F03-04 SUS316 |
| Sodium hydroxide, acetic acid, dilute sulfuric acid, dilute hydrochloric acid | Hastelloy B                      | F03-60 HASB        | F03-01 HASB   | 3 lines | F03-02 HASB     | B     | F03-03 HASB   | B     | ---           |
| Sea water, ammonia water, nitric acid   | Hastelloy C                      | F03-60 HASC        | F03-01 HASC   | 4 lines | F03-02 HASC     | C     | F03-03 HASC   | C     | ---           |
| Acetic acid, dilute sulfuric acid, sea water                                  | Titanium                         | F03-60 CHITAN      | F03-01 CHITAN                                       | 5 lines | F03-02 CHITAN   | T     | F03-03 CHITAN | T     | ---           |


- Note:**
1. An Electrode assembly consists of the following parts:  
 One Electrode (1 m)  
 One connecting nut  
 Two lock nuts  
 Two spring washers
  2. The material indication mark(s) are inscribed near the screw threads, and represent the material composition of the Electrode.
  3. Standard Electrodes are made of stainless steel and usable in purified water, sea water, sewage, acid (except acetic acid, sulfuric acid, etc.) and alkaline liquids. They may corrode depending upon the temperature and working conditions.
  4. Corrosion-resisting Electrodes made of SUS316 (AISI-316) and acid-resisting Electrodes made of titanium or hastelloy are also available.



5. When long Electrodes are required, connect them with connecting nuts and lock nuts (2 pieces) every 1 m.

## Electrode Separators

| No. of Electrodes | Model     |
|-------------------|-----------|
| 1                 | F03-14 1P |
| 3                 | F03-14 3P |
| 5                 | F03-14 5P |



When the required length of Electrode is more than 1 m, use a Separator at each joint of two Electrodes so as to prevent the Electrodes from contacting one another.

Use a one-pole type for BF Electrodes. The five-pole type can be used for PS-5S and PS-4S Electrodes.

Material: Ceramic

## Electrode Band

F03-05 3P, 4P, and 5P



Sheath: Vinyl chloride

Core: 0.3 dia. x 21, straight wire, SUS304


Length: 50 m max. (When ordering, specify the length by meters.)

The Electrodes come in three types: 3P, 4P, and 5P. Each of them require the following accessories that are separately sold.




| Accessories                | Weight (per 1) | Electrode     |               |               |
|----------------------------|----------------|---------------|---------------|---------------|
|                            |                | 3P            | 4P            | 5P            |
| Connecting nut             | Approx. 20 g   | 3             | 4             | 5             |
| Weight                     | Approx. 50 g   | 3 to 4        | 4 to 6        | 5 to 8        |
| End cap                    | Approx. 1 g    | 3             | 4             | 5             |
| Insulation Cap             | Approx. 10 g   | 2             | 3             | 4             |
| Adhesive                   | Approx. 5 g    | 1             | 1             | 1             |
| Electrode Band weight (1m) | ---            | Approx. 110 g | Approx. 140 g | Approx. 180 g |

- The Electrode Band consists of polyvinyl-chloride-covered (PVC) stainless-steel wires SUS304 (AISI-304) which are free from mutual contact. As the Electrode Band can be cut, mounted, and removed with ease, it is most suitable for deep wells.
- Applicable Electrode Holders: PS-3S, PS-4S, PS-5S, BF-3, BF-4, BF-5
- Ambient operating temperature: -10°C to 60°C (with no icing)
- The Electrode Band cannot be used in flowing water, liquids over 60°C, or liquids which corrode PVC or stainless steel.

### Application Example






## Other Accessories

| F03-11 Protective Cover  | F03-12 Spring Clamp   | F03-13 Mounting Frame for installing in concrete   |
|--|---|--|
| <p>Use this Cover for PS-series Electrode Holders with Mounting Frames (upper one in the following illustration), This Cover can also be used when installing the BF-series Electrode Holders outdoors. Since this Cover is not water-proof, water or dust may enter through the wire hole (lower one below).</p> <p>Applicable Electrode Holders:<br/>BF-3, BF-4, BF-5, PS-3S(R), PS-4S(R), PS-5S(R)</p>  <p>Weight: approx. 65g<br/>Operating temp.: -10°C to 70°C</p> <p>Two, M5 x 25 mounting screws</p> <p>Electrode</p> | <p>Used to clamp an Electrode Holder with ease, as shown in the illustrations, when the Electrode Holder is applied to a tank without a coupling. Squeeze the mounting frame into the Holder as shown below.</p> <p>Applicable Electrode Holders:<br/>PS-3S(R), PS-4S(R), PS-5S</p>  <p>Four, M5 x 25 mounting screws</p> <p>Electrode</p> | <p>Useful frame for burying in concrete. Cut as required based on the concrete depth.</p>  <p>Mounting Frame embedded into concrete</p> <p>Electrode</p> <p>Commonly used with Mounting Frame</p> |

## Mounting

## ■ PS-3S Electrode Holders

| 1. Mounting Electrode Holder  | 2. Attaching Electrode(s) to Electrode section  | 3. Inserting Electrode section into Electrode Holder  |
|---|---|---|
| <ul style="list-style-type: none"> <li>Screw the Electrode Holder into the coupling secured at the installation location.</li> </ul>              | <ul style="list-style-type: none"> <li>Insert each Electrode into the connecting nut, secure the Electrode with the clamp screws, and then tighten the lock nut.</li> <li>Connect the leads, inserted through the hole of the rubber bushing, into the respective terminals.</li> </ul> | <ul style="list-style-type: none"> <li>Fit the Electrode section into the Electrode Holder and secure it with the two screws.</li> <li>Check the Electrode section for proper wiring, fit the rubber bushing in position, and then cover the Electrode Holder with the drip-proof cover.</li> </ul> |
|  <p>Twin clockwise</p> <p>Electrode Holder</p> <p>Coupling</p> |  <p>Electrode section housing</p> <p>Rubber bushing</p> <p>Lock nut</p> <p>Electrode</p>   |  <p>Drip-proof cover</p> <p>Electrode section housing</p> <p>Electrode Holder</p>  |

**Note:** 1. OMRON does not sell couplings.


2. Screw in the Electrode until it reaches the bottom of the nut. Insufficient insertion will cause a faulty connection.




## ■ Installing PS-□S Electrode Holder on Tank

### 1. For tanks with thin walls combined with the F03-12 Spring Clamps

- Using the F03-12 as a nut




- Using the F03-12 as a flange




### 2. For tanks with thick metal walls

- Fabricate screw threads of the same size as for the PS-□S in the tank




### 3. For concrete tanks



## ■ Electrode Holder and Electrodes

### How to Mount Electrodes


#### Connecting Electrodes to Electrode Holders



**Note:** Clamp screw and spring washer are not provided for the BS-1T Electrode Holder (titanium, hastelloy B, or hastelloy C).

#### Connecting One Electrode to Another


When a long Electrode is required, use two or more Electrodes by jointing them with a connecting nut and two lock nuts at intervals of 1 m.




## ■ PH-1/PH-2 Electrodes

### PH-1

(See Notes 1 and 2)



### PH-2




- Note:**
1. When the distance between E1 and E3 exceeds 1 m for supplying purified city water, for example, locate a second E3 within 200 mm of E1.
  2. Even when the distance is less than 1 m, the product may not operate due to the water quality.

■ Electrode Bands


**Connecting Electrode Holder and Electrode Band**

Connect the connecting nut to the Electrode section as shown in the illustration below and secure the connecting nut with the clamp screw. Insert the Electrode Band into the lower hold of the connecting nut, and tighten the two clamp screws so that the conductor in the Electrode Band will come into contact with the connecting nut. Then mount the Electrode Holder to the Electrode section and secure them with two mounting screws, which are provided with the model.




**Mounting Weight(1)**

To mount an Electrode Band Weight on an Electrode Band, firmly tighten the two screws A or B. The needle screws will come into contact with the electrode wire (conductor) allowing the Electrode Band Weight to become an electrode plate. (Be sure to use screw holes A or B.). The Electrode has guides for connecting screws as shown by the arrows below so that connecting screws can be properly inserted into the conductor.




**Mounting Weight (2)**

Install Electrode Band Weights in three positions. The Electrode Band Weights work as short, medium, and long Electrodes, allowing the Electrode Band to detect high, medium, and low levels of liquid.




**Mounting Insulation Cap**

Cover each Electrode Band Weight with an Insulation Cap so as to prevent false detection due to contact between the Electrode and tank. Deform the Insulation Cap to an ellipsoid before installing it on the Electrode Band Weight.




**Mounting End Cap**

Cover the Electrode Band end and apply the Adhesive sold separately to prevent water from entering between the sheath and the End Cap.




In purified city water, if the distance between the long Electrode (E3) and short Electrode (E1) is more than 50 cm, install another Electrode Band Weight as E3 in the vicinity of E1 at intervals of 15 to 20 cm, referring to Mounting Weight (2) above. An Insulation Cap is not needed for the long Electrode.



### ■ Mounting the Protective Cover on the PS-series Electrode Holder


Attach the F03-12 Mounting Frame to the bottom of the PS-series Electrode Holder as shown below. Next, place the F03-11 Protective Cover on top of the Electrode Holder and press on it until a clicking sound is heard. For mounting purposes, the cap screw attached to the Protective Cover is not required.



### ■ Mounting the Protective Cover on the BF-series Electrode Holder (BF-3/4/5)

Remove the two mounting screws (M5 x 25) of the BF-series Electrode Holder and attach the two cap screws (M5 x 25) supplied with the F03-11 Protective Cover.

Next, put the Protective Cover over the top of the BF-series Electrode Holder, and then tighten the supplied two screws (M3 x 20 with washers). Refer to the following illustration.





## Dimensions


**Note:** All units are in millimeters unless otherwise indicated.

### ■ Standard Models



#### 61F-G




#### Mounting Holes





#### 61F-G1 61F-G2 61F-I




#### Mounting Holes





**61F-G3**




**Mounting Holes**



**61F-G4**






**Mounting Holes**







**■ Plug-in Models**

**61F-GP-N**






PF113A-E

**61F-GP-N8**







PF083A-E

**61F-G1P  
61F-G2P  
61F-IP**






**■ Ultra High-sensitivity Models**

**61F-UHS**







**61F-HSL**







**■ Solid-state Alternate Operation Relay**

**61F-APN2**




**■ Surge Suppressor Unit**

**61F-03B  
61F-04B**



■ Electrode Holders


PS-3S/-4S/-5S  
PS-3SR/-4SR/-5SR  
(see note)




**Note:** The PS-3SR, PS-4SR, and PS-5SR have built-in resistor of 6.8 kΩ and used for the two-wire 61F models.

PS-31

Weight: approx. 325 g



F03-31 Dust-preventive rubber cap (optional)  
Weight: approx. 20 g




**Mounting Holes**




**Note:** Standard holder construction includes three integral 300-mm-long Electrodes. However, a model having 1,000-mm-long Electrodes is available on request.

BF-1


Weight: approx. 125 g




**Mounting Holes**





**BF-3/-3R**  
**BF-4/-4R**  
**BF-5/-5R**




**BF-3**  
 Weight: approx. 420 g  
**BF-3R**  
 Weight: approx. 425 g







**BF-4**  
 Weight: approx. 520 g  
**BF-4R**  
 Weight: approx. 525 g







**BF-5**  
 Weight: approx. 710 g  
**BF-5R**  
 Weight: approx. 715 g



**BS-1**  
 Weight: approx. 70 g



**BS-1T**




\*This nut is made of Teflon  
 \*\*A connecting nut made of Hastelloy B, Hastelloy C, or titanium is not supplied with two M4 screws and thus has no holes for such screws.

|                 |              |              |              |              |              |
|-----------------|--------------|--------------|--------------|--------------|--------------|
| <b>Material</b> | SUS304       | SUS316       | Titanium     | HAS B        | HAS C        |
| <b>Weight</b>   | Approx. 55 g | Approx. 55 g | Approx. 45 g | Approx. 65 g | Approx. 60 g |



**PH-1**


(Approx. 140 g with a 1-m cord)



Cable OD: Vinyl 5.0 dia., Chloroprene 6.5 dia.

**PH-2**

(Approx. 235 g with a 1-m cord)



Cable OD: Vinyl, Hypalon 6.8 dia.


**Note:** Cable is supplied in lengths of 1, 5, 10, 15, 20, 30, 40, 50, 60, 70, 80, 90, or 100 meters.

■ **Electrode Separators**


| F03-14 1P for one pole | F03-14 3P for three poles | F03-14 5P for five poles |
|------------------------|---------------------------|--------------------------|
|                        |                           |                          |

■ **Electrode Bands**


**F03-05 3P, 4P, 5P**





Black printing (1 mm wide)  
Outer sheath: PVC  
Core: SUS304, 0.3 dia. x 21 twisted




**F03-06 Electrode Band Connecting Nut (SUS304)**



**F03-07 U-shaped Electrode Band Weight (SUS304)**



**F03-08 End Cap (Neoprene Rubber)**





■ Connecting Sockets

Available Models


| Model No. of Controller Unit | Track-mounted Socket | Back-connecting Socket |
|------------------------------|----------------------|------------------------|
| 61F-UHS                      | 8PFA1                | PL08                   |
| 61F-HSL                      | 8PFA                 | PL08                   |
| 61F-APN2                     | PF083A-E             | PL08                   |
| 61F-G1P<br>61F-G2P<br>61F-IP | 14PFA                | PL15                   |
| 61F-GP-N<br>61F-GPN-V50      | PF113A-E             | PL11                   |
| 61F-GP-N8                    | PF083A-E             | PL08                   |
| 61F-03B<br>61F-04B           | PF113A-E             | PL11                   |

Track-mounted Sockets


PF083A-E





Terminal Arrangement/  
Internal Connections  
(Top View)




Mounting Holes




8PFA





Terminal Arrangement/  
Internal Connections  
(Top View)




Mounting Holes




8PFA1




Terminal Arrangement/  
Internal Connections  
(Top View)




Mounting Holes




**14PFA**




**Terminal Arrangement/  
Internal Connections  
(Top View)**




**Mounting Holes**




**PF113A-E**



**Terminal Arrangement/  
Internal Connections  
(Top View)**





**Mounting Holes**




**Back-connecting Sockets**


**PL08**




**Terminal Arrangement/  
Internal Connections  
(Top View)**




**Mounting Holes**




**PL11**






**Terminal Arrangement/  
Internal Connections  
(Top View)**




**Mounting Holes**



PL15




Terminal Arrangement/  
Internal Connections  
(Top View)



Mounting Holes

Two, 3.5 dia. or M3 Controller  
Unit mounting holes




## ■ Mounting Brackets

When the 61F-G1P/-G2P/-IP/-UHS/-HSL is mounted with a Track-mounted Socket, the Controller is held secure by Mounting Brackets attached to the Socket.

### 61F-GP-N


To mount the 61F-GP-N or 61F-GPN-V50 on the PF113A-E Track-mounted Socket, use the PFC-N8 Mounting Brackets attached to the Socket as accessories.

#### PFC-N8



To mount the 61F-GP-N or 61F-GPN-V50 on the PL11 Back-connecting Socket, use the PHC-5 Mounting Brackets.


#### PHC-5



### 61F-03B/-04B


When mounting the 61F-03B/-04B on the PF113A-E Track-mounted Socket, use the PFC-A1 Mounting Bracket.

#### PFC-A1



To mount the 61F-03B/-04B Unit to the PL11 Back-connecting Socket, use the PLC-1 Mounting Brackets.


#### PLC-1



### 61F-GP-N8/61F-APN2



To mount the 61F-GP-N8/61F-APN2 on the PF083A-E, use the PFC-N8 Mounting Bracket.

#### PFC-N8






■ DIN Track Mounting Accessories



**DIN Track**  
PFP-100N  
PFP-50N






**End Plate**  
PFP-M



**DIN Track**  
PFP-100N2



**Spacer**  
PFP-S



- Note:**
1. The PFP-100N is 15 mm on both ends, while the PFP50N is 15 mm on one end and 5 mm on the other end.
  2. Indicates total DIN Track length.

- 1 m: PFP-100N
- 50 cm: PFP-50N
- 1 m: PFP-100N2


### ■ Connection with SE Motor Protective Relay Prevents Burnouts in Motors and Pumps



Static relay for protection of motors and pumps against problems due to overload, open phase, reverse phase, etc.

Applicable to all 61F-series Controllers except for 61F-I (indicator model).

#### Connection Example (When Combined with 61F-G)



## Application Examples

- Level control in tanks, reservoirs, sewage plants, underground wells, mixing plants etc.
- Level control for element protection in pipes, channels, and irrigation systems.
- Flow detection in pipes, channels, and irrigation systems.
- Ice bank control in cold drink dispensers, ice makers, water chillers, bulk milk tanks, etc.
- Dispensing of liquids by volume.
- Indication of liquid buildup due to filter blockages.
- Pollution/foul water detection for rivers, drains, etc.
- Alarm control warning of abnormal or dangerously high or low levels.

## 61F Selection Guidelines

- The limit of specific resistivity of a fluid controlled by the general-purpose model at an immersion depth not exceeding 30 mm is 30  $\Omega$ -cm, using PS-3S Electrode Holders. Use the high-sensitivity models (H type) for liquids with higher resistivity (see note 1). Refer to the resistivity values listed for water and other liquids in Table 1 and Table 3 when selecting the unit specification. The resistivity range detectable by the 61F is shown in Table 2. Refer to the information on the units and the fluid to be controlled when selecting the appropriate model.

- Note:**
1. The high-sensitivity models may suffer from resetting problems when used with certain types of water. In some cases it cannot substitute for the general-purpose models or low-sensitivity models. Be sure to select the model appropriate for the application.
  2. The circuit configuration of the 61F-□H high-sensitivity model is designed so that the relay de-energizes when there is water present across the Electrodes. When power supply voltage is applied, the internal relay turns to the NO contact and, when the electrode between E1 and E3 becomes conductive, the relay is reset to the NC contact. This contact operation is reverse for models other than the high-sensitivity models. Although the internal relay operates (and operation indicator turns ON) simply when the power supply voltage is applied, this operation is not abnormal. (The relay in the 61F-□NH energizes when there is water present across the Electrodes.)



### Caution

In case of the 61F-HSL ultra high-sensitivity variable model, malfunction due to electric corrosion may occur in the DC electrode circuit. Be careful not to use the product in such a way where current constantly flows between electrodes.

**Table 1 Water Resistivity Values  
(Japanese Reference Values)**

| Water type      | Resistivity                        |
|-----------------|------------------------------------|
| City water      | 5 to 10 $k\Omega \cdot cm$         |
| Well water      | 2 to 5 $k\Omega \cdot cm$          |
| River water     | 5 to 15 $k\Omega \cdot cm$         |
| Rain water      | 15 to 25 $k\Omega \cdot cm$        |
| Sea water       | 0.03 $k\Omega \cdot cm$            |
| Sewage          | 0.5 to 2 $k\Omega \cdot cm$        |
| Distilled water | 250 to 300 $k\Omega \cdot cm$ min. |

**Table 2 Detectable Resistivity Ranges**

| Model  | Resistivity (recommended values) |
|--|----------------------------------|
| Long-distance models (4 km)                      | 5 $k\Omega \cdot cm$ max.        |
| Long-distance models (2 km)                      | 10 $k\Omega \cdot cm$ max.       |
| Low-sensitivity models                           | 10 $k\Omega \cdot cm$ max.       |
| 2-wire models                                    | 10 $k\Omega \cdot cm$ max.       |
| General-purpose models                           | 10 to 30 $k\Omega \cdot cm$      |
| High-temperature models                          | 10 to 30 $k\Omega \cdot cm$      |
| High-sensitivity models (compact plug-in models) | 30 to 200 $k\Omega \cdot cm$     |
| High-sensitivity models (standard models)        | 30 to 300 $k\Omega \cdot cm$     |
| Ultra High-sensitivity models                    | 100 to 10 $k\Omega \cdot cm$     |

**Note:** The specific resistivity ranges of fluids to be controlled are given for the PS-3S at an immersion depth not exceeding 30 mm.

**Table 1A Conductance Values of Water**

| Water type      | Conductance              |
|-----------------|--------------------------|
| City water      | 100 to 200 $\mu S/cm$    |
| Well water      | 200 to 500 $\mu S/cm$    |
| River water     | 67 to 200 $\mu S/cm$     |
| Rain water      | 40 to 67 $\mu S/cm$      |
| Sea water       | 33,300 $\mu S/cm$        |
| Sewage          | 500 to 2,000 $\mu S/cm$  |
| Distilled water | 3.3 to 4 $\mu S/cm$ max. |



## Precautions

### ⚠ WARNING

Never touch any of the terminals. Doing so may result in electric shock.

Never attempt to disassemble the 61F or touch the inside of the 61F while the power is being supplied. Doing so may result in electric shock.

### ■ Correct Use

#### Use a Power Supply with Minimal Voltage Fluctuation

Avoid connection to a power supply with a voltage fluctuation greater than or equal to +10% or -15%.

#### Consider the Ambient Temperature

Do not install the 61F where it may be exposed to a temperature of 55°C or more and a humidity of 85% or more. In particular, install the 61F away from heat-generating equipment incorporating coils or windings. Also avoid locations subject to high humidity or corrosive gases.

#### Avoid Vibration and Shocks

Do not subject the 61F to vibration or shocks which can cause chattering problems. Do not install the 61F near contactors that generate severe shocks while the contactors are in operation.

#### Do Not Test with a Megohmmeter

During insulation resistance measurements, never apply the megohmmeter across the Electrode terminals.

#### Use Self-holding Electrodes

Use Self-holding (E2) Electrodes when contactor open/close control is carried out. If E<sub>1</sub> Electrodes are used, ripples on the liquid surface can cause incorrect contactor operation and damage to the contacts.

Be sure to turn OFF the power supply before replacing the plug-in models.

#### Short Wiring in Electrode Circuit

Keep the wires connecting the 61F to Electrode Holders as short as possible. If long leads are used, the floating capacity of the leads, and abnormal surges or noise in the Electrode circuit can cause malfunctions.

The thicker the cables, the shorter the permitted wiring length. The length of the cable connecting the 61F and Electrode described in the 61F datasheet will be available if a 600-V VCT0.75-mm<sup>2</sup>, 3-core cable is used. Test results indicate that the actual wiring length using VCT 3.5-mm<sup>2</sup>, 3-core cable laid over the ground is 50% of the indicated length for general-purpose applications and 80% of the indicated length for long-distance applications. When selecting the cable specification, remember that the wiring length is further decreased for underground cables and larger diameter cables because of the increased floating capacity with the ground.

#### Keep Power Cables Separate from the Electrode Circuit

Do not pass the leads for the Electrode circuit through the same duct, or near to, high-tension cables or power cables. This can cause noise which leads to malfunctions.

#### Ground Correctly

Ground the common Electrode terminal to reduce the effects of noise.

#### Use a Surge Suppressor

Connect a 61F-03B(-04B) Surge Suppressor with the 61F Electrode terminals to protect the circuit from surges. This is particularly important in lightning-prone areas. To further improve protection, install a commercial surge suppressor in the power supply to eliminate surges in the power system.

#### Consider the Response Times

The 61F requires a response time not exceeding 80 ms for operation or 160 ms for reset. Take these response times into account in cases where precise sequence control is required.

#### Consider the Liquids to Be Controlled

The 61F cannot be used for any liquid that has almost no conductivity such as sewage containing oil.

The 61F cannot be used for any flammable liquid such as gasoline, kerosene, or heavy oil.

#### Do Not Share Electrodes

Do not connect a single Electrode to more than one 61F. If the phases of the 8-VAC Electrode-circuit power supplies are opposite to each other, as shown in Fig. 1, an internal close circuit (return circuit) is created (indicated by the arrows). The 61F may malfunction regardless of the liquid level when the 61F power is turned ON. This problem can be overcome by matching the power supply phases, as shown in Fig. 2, but in this configuration the internal impedance of the 61F calculated from the Electrode will be approximately half as large as the internal impedance of a single 61F. The same phenomenon can occur if multiple (not shared) Electrodes, connected to separate 61F units, are installed close together inside a single tank. Maintain sufficient clearance between Electrodes connected to separate 61F units so that they do not interfere with each other. Common leads, however, can be connected to the ground Electrode.

Fig. 1 Internal Closed Circuit





Fig. 2 Match Phases




## ■ Cautions on Electrodes

Be sure to disconnect the 61F before conducting an insulation test on the Electrode circuit for inspection purposes.

When cutting an Electrode, be sure to chamfer cut surfaces of the electrode.


### Maintain a Clearance Between Electrodes

Maintain sufficient clearance (normally 1 m) between Electrodes in sea water or contaminated water. Use the 61F-□D (or -□ND) low-sensitivity models if this clearance is difficult to maintain.



### Long Ground Electrode

The Electrodes are mounted in sets of three. Connect the shortest Electrode to  $E_1$ , the medium Electrode to  $E_2$  and the longest Electrode to  $E_3$ . The longest Electrode,  $E_3$ , must be at least 50 mm longer than the other Electrodes.




### Consider the Operating Level

Due to the liquid type and fluctuations in the power supply voltage, the operating level may fluctuate to a small degree from the level at which the liquid surface makes contact with the Electrode tip.


### Use Separators

If the Electrode length reaches 1 m min., insert Separators at the joint positions to prevent the Electrodes touching each other in the liquid.



### Take Care When Taping the Electrodes

When applying vinyl tape to the Electrodes to prevent them touching each other in the liquid, leave at least 100 mm at the end of the rod untaped. Do not tape to the very tip.



### Mount Electrodes Vertically


Install the Electrodes vertically to avoid the accumulation of slime which can form an insulating layer on the Electrode surface.

## Keep Electrodes Clean

Lift the Electrodes and remove the surface film with fine sandpaper about 6 months after installation. Subsequently, repeat this cleaning once or twice per year.

Cleaning is particularly important for Electrodes used in a liquid containing large amounts of dirt or slime, which can build up into an insulating film on the Electrode surface and cause malfunctions. Clean the surface insulating film from Electrodes used in this environment once every three months. Use a pipe, as shown in the diagram below in situations where the water contains large amounts of dirt.

Use a pipe as shown to keep dirt and oil films from the Electrode in situations where the liquid is highly contaminated with dirt and oil, such as sewage holding tanks.




Use a pipe at least 4 inches in diameter.

Cut off the end of the pipe at an angle to clear the estimated amount of contaminants accumulating at the bottom of the tank.

Drill an approximately 10-dia. vent hole at the top of the pipe.

Using an Anti-ripple Pipe:

Use an anti-ripple pipe as shown below in cases where large ripples are produced by a rapid fluid flow rate.



Use a pipe at least 4 inches in diameter.

To improve liquid circulation inside the pipe, drill at least four 6 to 10-dia. holes as opposing pairs at the tip position of each Electrode.

Drill an approximately 10-dia. vent hole at the top of the pipe.

Follow the information above with regard to using Electrodes.

## ■ Cautions on Electrode Holders

Do not mount horizontally or a malfunction may occur.

### BS and BF Electrode Holders

When installing the Electrodes, first tighten the connection nut with a wrench before tightening the Electrodes and lock nut. Tightening the terminals or other parts can lead to damage of the insulating parts due to tightening torque.

When mounting a BS-1 Electrode Holder to a boiler, wrap Teflon tape 2 or 3 times around the mounting position and use the gasket supplied.


Always apply the F03-11 Protective Cover if the BF-3 (-4 or -5) is used outside or in a position subject to water splashes or where dust or dirt can settle. Foreign matter on the Electrode insulation can cause electrical leakage and malfunctions.

## ■ Inspecting the Electrode Circuits

In cases where the Electrodes cannot be withdrawn to test the Electrode circuit, a tester can be used to measure the resistance between the Electrode and ground, as shown in the diagram below. The measured resistance value indicates the length, contact condition, and mounting condition of the Electrode. For example, the sequence of Electrodes ordered from low measured resistance to high is  $E_3$  (long),  $E_2$  (medium), and  $E_1$  (short).


Follow the guidelines below to use this test method.

1. Detach the leads from the 61F.
2. Measure the conducting status with the tank full. (The water level must be at  $E_1$  minimum.)
3. Measure the insulating status with the tank empty. (The water level must be at  $E_3$  maximum.)



## ■ Measuring the Resistance Between Electrodes

Measure the resistance between the Electrodes if the wiring is correct but the 61F does not operate. Measure with a voltmeter using the voltage drop method, as shown below.



An ammeter able to read approximately 1 mA with as low an impedance as possible.



A voltmeter able to read a value of several volts with as high an impedance as possible.

The resistance between Electrodes (resistance of liquid between  $E_1$  and  $E_3$ ) is given by the following equation.

$$R = V/I$$

Where,

R: resistance of liquid between Electrodes ( $\Omega$ )

V: voltmeter indicated voltage (V)

I: ammeter indicated current (mA)

Select the 61F model according to the R (resistance) value.

## ■ Inspecting the 61F-11N Relay Unit

Apply the specified power supply voltage with the Relay Units connected to the 61F. Refer to the connection diagrams (internal wiring diagrams) and short the 61F ground terminal to the operating terminal of each Relay Unit. Check the operation of the relay output contacts with a tester. With the 61F-11 models, the indicator will be lit when the Relay Unit operates.

## Water Leak Alarm/Detector

61F-WLA/-GPN-V50

### Eliminate Problems Caused from Water Leakage

- 0 to 50 kΩ variable operating resistance to detect virtually any liquid.
- Two types available: Water Leak Alarm (61F-WLA) and plug-in Water Leak Detector (61F-GPN-V50).
- 24 VAC interelectrode voltage causes no electrolytic corrosion.
- Suggested applications include computer room, power plant, factory, library, warehouse, and basement use.
- Conforms to EMC/IEC Standards (61F-GPN-V50).
- Approved by UL/CSA (61F-GPN-V50)



### Ordering Information

|                     |             |
|---------------------|-------------|
| Water Leak Alarm    | 61F-WLA     |
| Water Leak Detector | 61F-GPN-V50 |

When ordering, to complete the part number, be sure to specify the desired operating voltage.

Example: 61F-WLA [120/240 VAC]

\_\_\_\_\_ Desired supply voltage

### Specifications

#### ■ Ratings/Characteristics

| Item                      | Water Leak Alarm                                       | Water Leak Detector                                    |
|---------------------------|--|--|
| Model                     | 61F-WLA  | 61F-GPN-V50  |
| Supply voltage            | 100/200, 110/220, 120/240 VAC                          | 100, 110, 120, 200, 220, 240 VAC                       |
| Interelectrode voltage    | 24 VAC   |  |
| Operating current         | 3 mA (AC) max.   |  |
| Power consumption         | 8.0 VA max.  | 3.2 VA max.  |
| Sensitivity               | Variable (0 to 50 kΩ)                                  |  |
| Error (against the scale) | Scale 0: 10 kΩ<br>Scale 50: ±10 kΩ (see note 2)        | Scale 0: 10 kΩ<br>Scale 50: ±10 kΩ (see note 2)        |
| Contact ratings           | 3 A 250 VAC, SPDT cosφ=1<br>1 A 250 VAC, SPDT cosφ=0.4 | 3 A 250 VAC, DPDT cosφ=1<br>1 A 250 VAC, DPDT cosφ=0.4 |
| Indicator                 | Provided (Power and Leak indicators)                   | Provided (Operation indicator)                         |
| Alarm buzzer              | Provided   | Not provided   |
| Test switch               | Provided   | Not provided   |
| Ambient temperature       | -10°C to 55°C  |  |


**Note:** 1. For detecting leakage of water with high resistivity, use 61F-UHS or 61F-HSL ultra high-sensitivity models. (Refer to page 32.)

2. The Detector may not operate around the setting value of "0." Adjust the sensitivity depending on the actual application.

# Operation

## Internal Circuit


61F-GPN-V50 Water Leak Detector



# Operating Principle

When the two conductive cores of the Sensor Cable are contacted by a liquid, a weak alternating current (as small as 3 mA max.) flows across the cores. This current is amplified to operate a relay.

In practice, leakage will be detected if water drops are present between the core wire and the Electrode (F03-15 Sensor Cable) or detecting section (F03-16 Sensor Cable). (Refer to the specifications on page 70)




## Sensor Cable Protective Cover

| Item          | F03-25  | F03-26  |
|---------------|---|---|
| Appearance    |   |   |
| Suggested use |   |   |
| Construction  |   |   |
| Comments      | Fixes the F03-15 Sensor Cable on the floor surface. Attach the sticker on a smooth surface. To attach it on a concrete floor, use a concrete bonding agent. | Fixes the F03-16 Sensor Cable on the floor surface. Attach the sticker on a smooth surface. To attach it on a concrete floor, use a concrete bonding agent. |


# Dimensions

**Note:** All units are in millimeters unless otherwise indicated.

## 61F-WLA Water Leak Alarm




## 61F-GPN-V50 Water Leak Detector




## ■ Accessories (Order Separately)

### Connecting Sockets (for 61F-GPN-V50 Water Leak Detector)

#### PF113A-E Track-mounted Socket




#### PL11 Back-connecting Socket




**Important:** Install the Water Leak Detector socket with the keyway facing down.

## Sensor Cable

### F03-15




Sheath: Transparent vinyl chloride  
Core: Stainless steel SUS304



### F03-16




Sheath: Transparent vinyl chloride  
Core: Stainless steel SUS304




# Installation

## ■ Connections

### 61F-WLA Water Leak Alarm



### 61F-GPN-V50 Water Leak Detector



# Precautions

## ■ Correct Use

- (1) Use only F03-15 or F03-16 Sensor Cable. Other water conductors may cause the Water Leak Alarm/Detector to malfunction, or not operate at all because of mismatched sensitivity.
- (2) Place the Sensor Cable at a location where water leakage is most likely to occur. For example, consider the following locations:
  - Under a raised floor; on the highest floor of a building; on the ceiling
  - In the vicinity of an air conditioner, or on the floor near a humidifier
  - On the floor near a feed-water pipe, conduit; hot-water pipe.
  - On top of a power, or control panel
- (3) Secure the Sensor Cable so that they touch the floor surface or the wall near a pipe arrangement. Cover the Sensor Cable with a F03-25 or F03-26 Protective Cover if they are installed at a location crowded with people. However, place the cover such a manner that water can easily reach the Sensor Cable.
- (4) Keep the temperature at the installation site to within 55°C. Do not install the Water Leak Alarm/Detector/Sensor cable in the proximity of heat-generating equipment (such as that having a coil or wire winding). Also, do not use it in a highly humid location, or at a location that is subjected to corrosive gases. Do not place the Water Leak Alarm/Detector side-by-side with a high-capacity contactor that produces an inrush current when it operates, as such arrangement may cause chattering to occur, consequently causing a malfunction of the Water Leak Alarm/Detector.
- (5) Wiring distance of the Sensor Cable varies depending on the water quality. When using IV cables, wire the Sensor Cable to the length specified in the following table.
- (6) Mount the 61F-WLA Water Leak Alarm/Detector on a sturdy wall surface which is not subjected to vibration or shock. Do not use double-sided adhesive tape, otherwise, the Detector may detach when the adhesive tape deteriorates due to aging.
- (7) When wiring the Sensor on conductive objects like metal objects, use the F03-16.
- (8) When measuring insulation resistance, do not conduct a megger test between the electrode terminals.

| IV Cable     | Sensor Cable |
|--------------|--------------|
| 0 m          | 200 m        |
| 10 to 150 m  | 150 m        |
| 200 to 300 m | 100 m        |
| 350 to 400 m | 50 m         |

**Note:** IV cable: 2 mm<sup>2</sup>

**NOTE: DIMENSIONS SHOWN ARE IN MILLIMETERS. To convert millimeters to inches divide by 25.4.**

---

**OMRON**<sup>®</sup>**OMRON ELECTRONICS LLC**One East Commerce Drive  
Schaumburg, IL 60173**1-800-55-OMRON****OMRON ON-LINE**Global - <http://www.omron.com>USA - <http://www.omron.com/oei>Canada - <http://www.omron.com/oci>**OMRON CANADA, INC.**885 Milner Avenue  
Toronto, Ontario M1B 5V8**416-286-6465**